



Luminaire Schedule					
Symbol	Qty	LLF	Description	Type	Mounting Height
	6	0.930	DSX1 LED P9 40K BLC MVOLT (8' Mast Arm Required)	S1	25
	4	0.930	DSX1 LED P9 40K BLC MVOLT (8' Mast Arm Required)	S1A	25

Calculation Summary						
Label	CalcType	Units	Avg	Max	Min	Avg/Min
Parking Lot	Illuminance	Fc	4.84	8.2	0.3	16.13
Propert Line	Illuminance	Fc	0.34	5.8	0.0	N.A.
Sidewalk	Illuminance	Fc	1.35	2.6	0.7	1.93

**This document contains confidential and proprietary information of KSA Lighting & Controls. This document may only be used by or for the benefit of KSA Lighting & Controls representatives and customers. This lighting layout is not a professional engineering drawing and is provided for informational purposes only, without warranty as to accuracy, completeness, reliability or otherwise. KSA Lighting & Controls is not responsible for specifying the light fixtures or illumination requirements for any specific project, nor is it responsible for meeting municipal or building code requirements. It is the obligation of the end-user to consult with a professional engineering advisor to determine whether this lighting layout meets the applicable project requirements for lighting system performance, safety, suitability and effectiveness for use in a particular application. Field verification is recommended when calculations are based on end-user or customer-provided information. End-user environment and application (including, but not limited to, voltage variation and dirt accumulation) can cause actual field performance to differ from the calculated photometric performance represented in this lighting layout. In no event will KSA Lighting & Controls be responsible for any loss resulting from any use of this drawing.

- Notes :
1. Calculation Work Plane : Ground Level
 2. Fixture Mounting Height : 25'
 3. Calculation Point Spacing : 5' x 5' (10' x 10' Behind Property Line)